

**LEAD & COPPER RULE MONITORING AND REPORTING VIOLATION  
MANDATORY LANGUAGE - TIER III**

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

**BOIS D'ARC MUNICIPAL UTILITY DISTRICT** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During June 1, 2020 to September 30, 2020, we did not complete all testing for lead and copper and therefore cannot be sure of the quality of your drinking water during that time.*

The table below lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for lead and copper tap water sampling, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
<i>Lead and copper tap water sampling</i>	<i>Ten (10) samples once every three (3) years</i>	<i>Seven (7)</i>	<i>June 1 2020 - September 30, 2020</i>	<i>The 3 remaining samples were taken by October 2, 2020</i>

**What is being done?**

We are working to correct the problem. For more information, please contact Billy Stephens at 903-378-7361 or 14101 E. FM 1396, Honey Grove, TX 75446-5210.

Our system completed taking the remaining samples by October 2, 2020. All test results were below the action levels as set by the State of Texas (in compliance). Our system experienced no water quality issues during this time. Consumers do not need to take any additional action. We have made corrective actions to ensure that the next round of samples will be completed within the required sampling dates.

*Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the Bois D'Arc Municipal Utility District.

Public Water System Number: TX0740044

Date Distributed: March 5, 2021